



CK ELECTRICAL SERVICES
82 ROMAN BANK
MANSFIELD WOODHOUSE
NOTTINGHAMSHIRE NG19 9DF
Mob: 07957 113134

Date: 18.6.24

PORTABLE APPLIANCE TEST CERTIFICATE

PURSUANT.
Health and Safety at Work Act 1974
Management of Health and Safety at Work Act 1999
Electricity at Work Regulations 1989

EQUIPMENT BELONGING TO-

JEMSTONE LTD
Botany Commercial Centre
Mansfield
Nottingham
NG18 5NF

I hereby certify equipment listed on the enclosed register (items no. 000 to no. 232) has been tested by me using a ROBIN SMARTPAT 3500 device.

Such equipment passed tests comprising of –

- Visual Inspection of plug, flex, case exterior, switches.
- Insulation resistance test to regulation
- Earth bond test to regulation.

All tested equipment was labelled, initialled, and dated by me today.

A handwritten signature in black ink, appearing to be 'A. G.', is written over a blank space.

Signed.

Date. 18.6.24

Person conducting test.

Note: Any equipment not on enclosed certificate / register shall be deemed unsafe and should be taken out of service immediately.

Our office will contact you approximately 30 days before re-test is due.